
**VILLAGE OF SUGAR GROVE
BOARD REPORT**

TO: VILLAGE PRESIDENT & BOARD OF TRUSTEES
FROM: ANTHONY SPECIALE, DIRECTOR OF PUBLIC WORKS
BRAD MERKEL, DEPUTY DIRECTOR OF PUBLIC WORKS
SUBJECT: DISCUSSION: MALLARD POINT DRAINAGE
AGENDA: JANUARY 21, 2019 REGULAR BOARD MEETING
DATE: JANUARY 17, 2020

ISSUE

A representative from Trotter and Associates will present an update on the status of the Mallard Point Drainage investigation.

DISCUSSION

In August 2019 J&S Construction replaced approximately 400 feet of 24" storm sewer pipe within the Mallard Point Drainage System that had failed. Since that time staff has worked with Trotter to monitor the ground water levels throughout the subdivision. While the ground water levels have decreased, there are a few residents on the west side of Brookhaven Circle that back up to the Ogle Farm that have stated that their sump pumps continue to run. Staff and Trotter have looked at options to decrease the run times and believe one possible solution is to install a gravity drainage system that would connect to the footing drains in approximately nine houses. Scott Trotter will present the project details.

COST

Costs associated with this report are undetermined at this time, but are estimated at \$500,000 - \$600,000. The cost is unbudgeted,

RECOMMENDATION

The Village Board discuss the Mallard Point Drainage System repairs.